



CERTIFICATE OF CONFORMITY VARIATION

(The Directives under which this certificate was issued were repealed on 30 June 2003)

CERTIFICATE NUMBER BAS No. Ex 98D1229U Dated 30 September 1998

SIRA VARIATION NUMBER 2 (TWO) Dated 14 December 2006

VARIATION TO COMPONENT

To permit:

- 1 The introduction of an alternative armour clamp and armour clamping ring combination, both identified with the mark "Z", within gland sizes Os to E; this allows the cable glands to be used with steel or brass tape armoured cable that have a tape thickness range of 0.2 mm to 1.0 mm.

DESCRIPTIVE DOCUMENTS

Number	Sheet	Rev.	Date	Description
			(Sira Stamp)	
453-E-2	1 of 1	C	24 Nov 06	Armour clamp ring -E1XZ
453-F-2	1 of 1	C	24 Nov 06	Armour clamp cone -E1XZ
453-GA	1 of 1	D	24 Nov 06	General arrangement

ADDITIONAL CONDITIONS OF CERTIFICATION

None

File No. 51A15742

Report No. R51A15742A

This Variation and its schedules may only be reproduced in its entirety and without change


C Ellaby
Certification Officer

Sira Certification Service

Rake Lane, Eccleston, Chester, CH4 9JN, England

Tel: +44 (0) 1244 670900

Fax: +44 (0) 1244 681330

Email: info@siracertification.com

Web: www.siracertification.com